



SEIZ Pneumatic Glove Tester

Order number: EB-02545

Pneumatic glove tester for repeat testing.

The insulating gloves must always be checked before each use and a repeat test must be carried out every 6 months, as prescribed in the IEC 60903 standard.

- two grooves for fixing the glove
- push button on the bottom of the device
- flexible valve on the upper part of the device
- two rubber rings for securing the glove when inflating

height: 14 cm

diameter: 12.5 cm

weight: 675 g